

OFFICE OF THE SENIOR CHEMIST, PHED LABORATORY, BHARATPUR
REPORT OF THE CHEMICAL EXAMINATION

No.: Lab/ Tech/ 2023-2024/ 256

Date: 7-6-23

To,

Chairman,
 KBS Education Trust, NH-21,
 Near Sewar Bridge, Ludhawai Toll Tax,
 Bharatpur

Distt:-Bharatpur
 Tehsil:-Sewar

*This Sample was not
 Collected by Lab*

REFERENCE:- YOUR LETTER NO.1606/30.05.2023

Sample Taker:-Sh.Ram Nivas Sharma

DATE OF RECEIPT: - 30.05.2023

Date Of Examination: 01.06.2023

Date of Collection:- 30.05.2023

Note: - All Results except pH are in mg/L

CHARACTERISTIC	ANALYSIS VALUE	PERMISSIBLE VALUE AS PER BIS; 10500-2012	
		Desirable Limit	Permissible limit in absence of alternate source
Location of Source	T/W,DPS Wala,Vamanpur,Sewar		
Lab Sample No.	244		
1. pH	7.1	6.5 - 8.5	6.5 - 8.5
2. Turbidity (NTU)	Clear	1	5
3. Colour	None	5	15
4. Odour	N.D.	Agreeable	Agreeable
5. Total Alkalinity(as CaCO ₃)	230	200	600
6. Total Hardness (as CaCO ₃)	170	200	600
7. Calcium Hardness (as CaCO ₃)	60	-	-
8. Magnesium Hardness (as CaCO ₃)	110	-	-
9. Chloride (as Cl ⁻)	90	250	1000
10.Sulphate (as SO ₄)	-	200	400
11.Nitrite (as NO ₂)	-	-	-
12.Nitrate (as NO ₃)	8	45	No Relaxation
13.Fluoride (as F ⁻)	0.32	1.0	1.5
14.Total Dissolved Solids	598	500	2000
15.Iron	-	0.2	1.0

CAJ
 Senior/Junior Chemist
 PHED Lab, Bharatpur

Date

No.: Lab/ Tech/ 2023-2024/

Copy to: -

1.The Chief Chemist, PHED Rajasthan, Jaipur.

Senior/Junior Chemist
 PHED Lab, Bharatpur

OFFICE OF THE SENIOR CHEMIST, PHED LABORATORY, BHARATPUR**BACTERIOLOGICAL EXAMINATION REPORT OF WATER**

No.:- Lab/ Tech/ 2023 -2024/ 257

Date: - 7-6-23

To,
 Chairman, KBS Education Trust,
 NH-21, Near Sewar Bridge,
 Ludhawai Toll Plaza, Bharatpur

DISTRICT: - Bharatpur
 TEHSIL: - Sewar


This Sample was not
 Collected by Lab

Reference:-Your Letter No.1606/30.05.2023

Collected By:-Sh.Ram Nivas Sharma

Sample No.	Date & Time of Collection	Date of Examination	Residual Chlorine (mg/L)	Particulars of Samples	Coliform Organism MPN per 100 ml.	Remark
422	30.05.2023	30.05.2023	-	T/W,DPS WALA,VAMANPURA,SEWAR	Nil	Satisfactory

No.: Lab/ Tech/ 2023-2024/
 1.The Chief Chemist, PHED, Lab., Raj. Jaipur.


 Senior/Junior Chemist
 PHED Lab, Bharatpur
 Date:-

Senior/Junior Chemist
 PHED Lab, Bharatpur

CERTIFICATE REGARDING SAFE DRINKING WATER AND SANITARY CONDITION


CERTIFICATE

No : - 1673

Date : - 02-05-23

It is certified that an inspection team headed by Rajveer Singh Assistant Engineer (Name of Officer with designation) from PHED City Sub Division East Bharatpur (Name of Department & Office) inspected the Delhi Public School, Bharatpur (Raj.) (Name & Address of the School) on 24-03-2023 and found that the Delhi Public School, Bharatpur (Raj.) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitary condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

This certificate is valid for a period of one year i.e. (from 02-05-2023 to 01-05-2024)


Signature With Seal
सहायक अभियन्ता
जन स्वास्थ्य अभि० विभाग
Name शहर उपखण्ड (पूर्व) भरतपुर
Designation

To,
Delhi Public School
NH-21, Near Sewar Bridge, Bharatpur (Raj.)
(Name & Address of the institution)